

# DISTRICT WATER TESTING LABORATORY, PATHANKOT

District Administrative Complex, 1st Floor, D Block, Room No.235, Pathankot.  
dwtpk1@gmail.com

## TEST REPORT

Name & Address of Customer  
Sanjay Dhoundiyal  
Pathankot

Customer Reference No. No : 4002/W/E24 Dated : 11/04/2022  
Sample Submitted by 9988547167  
Date of Sample Receipt 11/04/2022  
Analysis Starting Date 11/04/2022  
Analysis completion Date 12/04/2022

Chemical Testing  
Discort No.: DWTLPTK/2223/00004  
Tration no.: DWTLPTK/REG2223/00009  
Source : NA  
Scheme : NA  
Village : NA  
Block: NA  
Latitude : NA

Group: Water  
Date of Issue : 19/04/2022  
Condition of Sample : Unsealed  
Quantity/Type of Bottle: 500 ml / Plastic Bottles  
Location/Depth : Air Force Pathankot T/W no. 32 / NA  
Habitation : NA  
District : Pathankot  
Longitude: NA

Sample Type: Water

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.2	6.5-8.5	No Relaxation	--	IS 3025 (Part 11)
2	Colour	2	5	15	Hazen	IS 3025 (Part 4-2021)
3	Odour	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5)
4	Taste	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5)
5	TDS	220	500	2000	mg/l	IS 3025 (Part 16)
6	Turbidity	0.19	1	5	NTU	IS 3025 (Part 10-1991)
7	Alkalinity	116	200	600	mg/l	IS 3025 (Part 23)
8	Hardness	128	200	600	mg/l	IS 3025 (Part 21)
9	Calcium	41.68	75	200	mg/l	IS 3025 (Part 40-1991)
10	Magnesium	5.83	30	100	mg/l	APHA (23rd Ed. 2017) Calc
11	Chloride	5.99	250	1000	mg/l	IS 3025 (Part 32-1991)

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, R = Reaffirmed)
5. \* Value not available or test not performed for this parameter.

4  
*Pankaj*  
Principal  
केन्द्रीय विद्यालय नो  
Kendriya Vidyalaya No  
पथानकोट

*Pankaj*  
Mr. Pankaj Kumar  
Quality Manager  
Authorized Signatory  
For, District Water Testing Laboratory,  
Pathankot